



# MUNICIPAL CORPORATION CHANDIGARH

(Public Health Laboratory at Water Works Sector - 39)

## TEST - REPORT

Not for legal use

Lab No. : MCPHL/26/ 895

Date : 13.04.2026


Ref. No.	Sample Details	Date & Time
GMSH/11/2026/07		
Dated : 06.04.2026		
Issued to : The Headmistress Govt. Model High School, Sector - 11, Chandigarh.	Collected By	Laboratory Staff
Location : From School tap of Govt. Model High School, Sector - 11, Chandigarh	Collection Date	09.04.2026 06:55 a.m.
Packing : Polypropylene and glass bottle	Received at Lab	09:15 a.m.


### Test Result (As Per BIS 10500:2012)

S.No	Examination	Quality Standard	Unit	Result
1	pH	6.5 - 8.5	—	7.75
2	Odour	Agreeable	—	Agreeable
3	Taste	Agreeable	—	Agreeable
4	Turbidity	<1	N.T.U.	0.7
5	Total Dissolved Solids	<500	mg/l	146
6	Residual Chlorine	0.2 - 0.4	mg/l	0.2
7	Total Alkalinity (as CaCO <sub>3</sub> )	<200	mg/l	94
8	Total Hardness (as CaCO <sub>3</sub> )	<200	mg/l	88
9	Chlorides (as Cl )	<250	mg/l	04
10	Free & Saline Ammonia	NIL	mg/l	NIL
11	M.P.N. of Coliform Bacilli / 100ml of water	Zero	M.P.N.	0 (Excellent)

Payment received vide receipt No. 04/2026-27/311772, dated 08.04.2026, amount Rs.-3300/-

**Note:** - Water sample is found "POTABLE".


  
Chemist,  
M.C.P.H. Laboratory,  
Chandigarh.


  
Sub Divisional Engineer,  
M.C.P.H. Sub Division No.1,  
Chandigarh.

Endst. No. MCPH/26/-----

Dated : 13.04.2026

Copy forwarded to the Medical Officer of Health Municipal Corporation, Sector -17, Chandigarh for Information please.

  
Chemist,  
M.C.P.H. Laboratory,  
Chandigarh.

  
Sub Divisional Engineer,  
M.C.P.H. Sub Division No.1,  
Chandigarh.

### Remarks:-

- The results given above are related to the sample as collected and tested in lab.
- The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- The test report can't be used for any publicity or legal purpose.

----- End of Report -----

WATER IS LIFE, SAVE IT